



Graver Technologies

Filtration | Separation | Purification

# MetSorb® HMRG Outperforms Competitive Products

## MetSorb® HMRG outperforms competitive products in pilot study for removal of arsenic from drinking water

Elevated concentrations of arsenic are found in many regions of the world. Naturally occurring arsenic in drinking water affects about 10% of the drinking water supplies in the United States, especially groundwater supplies. One of those supplies is located in Hopewell, New Jersey. Graver, in conjunction with researchers from Stevens Institute of Technology and scientists from the New Jersey Department of Environmental Protection, conducted a pilot test of the well water to demonstrate an efficient and economical way to reduce the arsenic levels.

### Typical Water Analysis

Arsenic	40 parts per billion (ppb)
Arsenic V	37 ppb
Arsenic III	3 ppb
pH	7.9
Silica	20 mg/L (ppm)
Sulfate	60 mg/L (ppm)

### The Testing


Several adsorptive media (an iron based product, activated alumina, modified activated alumina, and MetSorb® HMRG) were tested side by side on the Hopewell well water in identical test units.

All were tested with an empty bed contact time of three minutes and the units were run beyond a breakthrough of arsenic in the effluent water of 10 ppb (the new Federal standard for allowable arsenic in drinking water). No preconditioning of the water was done.

### Test Results

Based on these tests, the treatment capacity decreased in the following order:  
MetSorb® HMRG > Iron based media > Modified activated alumina > Activated alumina.

See the table for the total treated number of bed volumes prior to breakthrough.



### Results Table: Breakthrough Volumes to 10 ppb

Media	Bed Volumes
MetSorb® HMRG	42,000
Iron based media	22,000
Activated alumina	2,000
Modified activated alumina	8,000

The complete breakthrough curves are shown in the graph as well, and clearly indicate the superiority of the MetSorb® HMRG in removing the arsenic.

Operating costs of the MetSorb® HMRG system are estimated to be substantially lower than for the other adsorptive media. These costs comprise mainly the periodic replacement of the media and the disposal of the spent media (typically adsorptive media for arsenic removal are not regenerable but rather a one time use). The use of the media is therefore optimized by running two adsorbers in series in a lead/lag mode, thereby allowing a greater utilization of the capacity of the MetSorb® HMRG. The spent MetSorb® HMRG has been tested by the Toxicity Characteristic Leach Procedure, and has been determined to be nonhazardous waste.

The operating cost is also very dependent on the inlet levels of arsenic; as might be expected, lower operating costs are seen for an inlet of 15 ppb of arsenic than for 50 ppb.

### For more information

MetSorb® HMRG Customer Service: 1-800-533-6623



Graver Technologies

200 Lake Drive, Glasgow, DE 19702 U.S.A.  
302-731-1700 • 800-533-6623 • Fax: 302-369-8356  
e-mail: info@gravertech.com • www.gravertech.com

Member of:



American Water Works Association  
The Authoritative Resource on Safe Water™

Water Quality Association

Rural Water Association

All information and recommendations appearing in this bulletin concerning the use of products described herein are based on tests believed to be reliable. However, it is the user's responsibility to determine the suitability for his own use of such products. Since the actual use by others is beyond our control, no guarantee, expressed or implied, is made by Graver Technologies as to the effects of such use or the results to be obtained. Graver Technologies assumes no liability arising out of the use by others of such products. Nor is the information herein to be construed as absolutely complete, since additional information may be necessary or desirable when particular or exceptional conditions or circumstances exist or because of applicable laws or government regulations.



A Marmon Water/Berkshire Hathaway Company